


PERSON/UNIT NOTIFIED		<b>SECRET</b> (When Filled In) GROUP 1 EXCLUDED FROM AUTOMATIC DOWNGRADING AND DECLASSIFICATION		ROUTING AND/OR INITIALS-SEEN BY 1 5 2 6 3 7 4 8	
ADVANCE COPY <input type="checkbox"/> ISSUED <input type="checkbox"/> SLOTTED		REPRODUCTION OF THIS COPY PROHIBITED			
BY: _____ AT: _____ Z		INDEX: <input type="checkbox"/> YES <input type="checkbox"/> NO			
DISSEM BY 15 PER _____ # _____		CLASSIFY TO CS FILE NO. _____			
ACTION UNIT <u>LOGS 4</u>		X-REF TO CS FILE NO. _____			
ACTION NO. <u>123</u>		<input type="checkbox"/> FILE RID <input type="checkbox"/> RETURN TO _____ BRANCH _____			
FILE, VR <u>Commo 7, DDS 2, PPB, SECUR 4</u>		25X1A			

SECRET 040730Z SEP 69 CIT 1192

4 SEP 69 IN 36790 25X1A



25X1A

POWER HOUSE AND AIR CONDITIONING PROJECT PROGRESS

25X1A

REPORT NO. 12.

1. PROJECT REPORTEDLY 82.6 PER CENT COMPLETE AS OF 15 AUGUST.
2. CONTRACTOR RECENTLY BEGAN FINAL CLEAN-UP WORK IN POWER HOUSE.
3. CONDUIT RUNS FOR SMOKE DETECTORS BEING INSTALLED THROUGHOUT BUILDING.
4. FOUNDATION FOR INCINERATOR ADDITION TO MAIN BUILDING ABOUT TO BE POURED.
5. RE-ASSEMBLY OF AIR CONDITIONING EQUIPMENT AROUND NEW CHILLER UNITS NEARING COMPLETION.
6. SITE WORK FOR NEW HARDSTAND AND SURROUNDING WALL ABOUT ONE-THIRD COMPLETED.
7. SECOND AIR-COOLED CONDENSER IN POSITION AND PIPING NEARLY COMPLETED.

RECD

DC  
EX  
SAC  
SA  
C/RE  
RO

SECRET

Weekly Report Done

SECRET

25X1A